

**Building Name:** Colman Hall  
**Street Address:** 212 S. Durkee St.  
**Year Built:** 1956  
**Occupancy:** Residence Hall  
**Capacity:** 156 Beds  
**Type of Construction:** Masonry, Steel, Concrete

### **Fire Alarm System Description**

**Fire Alarm Panel:** Honeywell Silent Night IST-1000

**General Description:** Fire alarm system consists of manual pull stations, visual/audible alarm devices and integrated automatic detection devices; addressable smoke detector/sounder bases and heat detectors located in individual sleeping rooms, corridors, common areas and mechanical spaces.

### **Fire Alarm Testing and Inspection**

Individual components of the fire alarm systems are tested annually by a certified fire alarm company in accordance with NFPA 72, National Fire Alarm Code.

### **Fire Suppression Equipment**

#### **Portable Fire Extinguishers**

Fire extinguishers are located in accordance with NFPA 10, Standard for Portable Fire Extinguishers.

#### **Portable Fire Extinguisher Inspections**

Fire extinguishers located in residence halls are inspected monthly by the LU Campus Security Office. Annual inspection is conducted by a qualified vendor in accordance with NFPA 10, Standard for Portable Fire Extinguishers.

### **Fire and Evacuation Drills**

Residence Halls are required to have at least one scheduled fire drill per month.

### **Emergency Power**

Colman Hall is equipped with an emergency generator designed to automatically activate when there is a power loss. The generators will operate life safety systems including all fire safety equipment, hallway lighting, emergency exit doors, and lighting in all emergency exit stairwells.